



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

On the use of hot-sphere anemometers in a highly transient flow in a double-skin facade

Jensen, Rasmus Lund; Larsen, Olena Kalyanova; Hyldgård, Carl Erik

Published in:
Proceedings of Roomvent 2007

Publication date:
2007

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):

Jensen, R. L., Kalyanova, O., & Hyldgård, C-E. (2007). On the use of hot-sphere anemometers in a highly transient flow in a double-skin facade. In O. Seppänen, & J. Säteri (Eds.), Proceedings of Roomvent 2007: Helsinki 13-15 June 2007 : Abstract Book (pp. 246). FINVAC ry.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- ? Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- ? You may not further distribute the material or use it for any profit-making activity or commercial gain
- ? You may freely distribute the URL identifying the publication in the public portal ?

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

On the use of hot-sphere anemometers in a highly transient flow in a double-skin facade

Rasmus Lund Jensen, Olena Kalyanova, Carl Erik Hyldgaard

Department of Civil Engineering
Aalborg University
Sohnsgaardsholmsvej 57
DK-9000 Aalborg, Denmark

Corresponding email: rlj@civil.aau.dk

1. Introduction

Hot-sphere anemometers are widely used for measurement of air velocity in the occupied zone. In this paper, the ability of hot-sphere anemometers to measure transient flow in a Double-Skin Façade (DSF) is investigated. When hot spheres are used in a DSF, the conditions are very different from the measurement of air velocity in the occupied zone. The velocity is higher and the flow is more transient, the anemometer is subjected to high loads of direct solar radiation and wide temperature ranges and, finally, the direction of the flow is important.

2. Methods

There are three test cases described in the paper. Each test case provides knowledge on one specific feature of the hot-sphere anemometer and all the test cases together give a background for an application of hot spheres for air flow/velocity measurements in the DSF cavity.

1. The response of hot-sphere anemometers to the flow dynamics is tested by placing the anemometer in the laminar air flow generated by a jet-wind tunnel. By means of a crank movement the sensor is oscillated back and forth in the air flow and overlaps the laminar flow with an almost pure sine wave. Readings from the hot-sphere anemometer are compared for different frequencies of oscillation.

2. Temperature compensation is the working principle of anemometers. The ability to compensate for different temperatures when exposed to solar radiation is investigated in a controlled environment using a powerful lamp

as a radiant heat source. Readings from the hot-sphere anemometer subjected to the high radiant heat flux are compared with the readings when no flux added.

3. In the Double-Skin Façade both upward and downward flow will occur and therefore it is important to determine the direction of the flow, meanwhile the exact angle of flow direction is insignificant. A simple method to register the flow direction using two hot-sphere anemometers separated by a small plate is tested and explained.

3. Conclusions

According to the experimental results, hot-sphere anemometers respond well to the fluctuations up to 1Hz, but the amplitude of measured velocities becomes smaller at the frequency of 1.6 and 2Hz. Particularly, problems can be noticed when the low velocities are to be measured (0.05 m/s), which is explained by the time constant of the sensor having the largest influence on the readings at the minimal velocities.

The hot-sphere anemometers do not change their performance when exposed to direct solar radiation. Even in the range of low velocities it was not possible to distinguish any influence from the radiative heat flux.

It is possible to use two hot-sphere anemometers separated by a plate to distinguish flow direction in the DSF cavity. The best results were obtained with a 7 by 7 cm plate and a spacing of 3 cm between the hot spheres and the plate.